

Emission Test Certificate

Friday June 16th, 2006

Supplier: Interface Australia Pty Ltd (4 Henry Street, Picton NSW 2511)

Sample Description: Nylon face fibre with Graphlar backing (sample 1A)

Date Tested: May/June 2006

Test Method: Carpet & Rug Institute Green Label Plus test program incorporating
ASTM D5116-97 "Standard Guide for Small-Scale Environmental Chamber
Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

<p>Carpet & Rug Institute Green Label Plus Specification</p>	<p>Nylon Face Fibre Graphlar Backing (1A) The results for Graphlar 1A can be considered representative of the whole range of solution dyed nylon modular carpet with Graphlar backing</p>
<p>Total Volatile Organic Compound emission rate < 0.5 mg/m²/hr (14 days)</p>	<p>Total Volatile Organic Compound emission rate 0.048 mg/m²/hr (14 days)</p>
<p>“Chemicals of Concern”:</p> <ul style="list-style-type: none"> Formaldehyde Acetaldehyde Benzene Caprolactam 2-Ethylhexanoic Acid 1-Methyl-2-Pyrrolidinone Naphthalene Nonanal Octanal 4-Phenylcyclohexene Styrene Toluene Vinyl Acetate 	<p>Emission Rate:</p> <ul style="list-style-type: none"> 0.003 mg/m²/hr <0.001 mg/m²/hr <0.005 mg/m²/hr <0.005 mg/m²/hr <0.025 mg/m²/hr <0.010 mg/m²/hr <0.005 mg/m²/hr <0.005 mg/m²/hr <0.005 mg/m²/hr <0.005 mg/m²/hr 0.005 mg/m²/hr <0.005 mg/m²/hr <p>The “chemicals of concern” were present in the product to a very low extent and would pose insignificant health effect to building occupants when used in the typical manner.</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ, ACA, AIRAH, FMA
Managing Director and Principal Consultant